- (1) 86 nanograms per joule heat input (0.20 lb per million Btu) derived from gaseous fossil fuel.
- (2) 129 nanograms per joule heat input (0.30 lb per million Btu) derived from liquid fossil fuel, liquid fossil fuel and wood residue, or gaseous fossil fuel and wood residue.
- (3) 300 nanograms per joule heat input (0.70 lb per million Btu) derived from solid fossil fuel or solid fossil fuel and wood residue (except lignite or a solid fossil fuel containing 25 percent, by weight, or more of coal refuse).

(4) 260 nanograms per joule heat input (0.60 lb per million Btu) derived from lignite or lignite and wood residue (except as provided under paragraph (a)(5) of this section).

(5) 340 nanograms per joule heat input (0.80 lb per million Btu) derived from lignite which is mined in North Dakota, South Dakota, or Montana and which is burned in a cyclone-fired unit.

(b) Except as provided under paragraphs (c) and (d) of this section, when different fossil fuels are burned simultaneously in any combination, the applicable standard (in ng/J) is determined by proration using the following formula:

$$PS_{\text{NOx}} = \frac{w(260) + x(86) + y(130) + z(300)}{w + x + y + z}$$

where:

PS<sub>Nox</sub>=is the prorated standard for nitrogen oxides when burning different fuels simultaneously, in nanograms per joule heat input derived from all fossil fuels fired or from all fossil fuels and wood residue fired; w= is the percentage of total heat input derived from lignite;

*x*= is the percentage of total heat input derived from gaseous fossil fuel:

rived from gaseous fossil fuel; y= is the percentage of total heat input de-

rived from liquid fossil fuel; and z= is the percentage of total heat input derived from solid fossil fuel (except lignite).

(c) When a fossil fuel containing at least 25 percent, by weight, of coal refuse is burned in combination with gaseous, liquid, or other solid fossil fuel or wood residue, the standard for nitrogen oxides does not apply.

(d) Cyclone-fired units which burn fuels containing at least 25 percent of lignite that is mined in North Dakota, South Dakota, or Montana remain subject to paragraph (a)(5) of this section regardless of the types of fuel combusted in combination with that lignite.

[39 FR 20792, June 14, 1974, as amended at 41 FR 51398, Nov. 22, 1976; 43 FR 9278, Mar. 7, 1978; 51 FR 42797, Nov. 25, 1986]

# § 60.45 Emission and fuel monitoring.

- (a) Each owner or operator shall install, calibrate, maintain, and operate continuous monitoring systems for measuring the opacity of emissions, sulfur dioxide emissions, nitrogen oxides emissions, and either oxygen or carbon dioxide except as provided in paragraph (b) of this section.
- (b) Certain of the continuous monitoring system requirements under paragraph (a) of this section do not apply to owners or operators under the following conditions:
- (1) For a fossil fuel-fired steam generator that burns only gaseous fossil fuel, continuous monitoring systems for measuring the opacity of emissions and sulfur dioxide emissions are not required.
- (2) For a fossil fuel-fired steam generator that does not use a flue gas desulfurization device, a continuous monitoring system for measuring sulfur dioxide emissions is not required if the owner or operator monitors sulfur dioxide emissions by fuel sampling and analysis.
- (3) Notwithstanding §60.13(b), installation of a continuous monitoring system for nitrogen oxides may be delayed until after the initial performance tests under §60.8 have been conducted. If the owner or operator demonstrates during the performance test that emissions of nitrogen oxides are less than 70 percent of the applicable standards in §60.44, a continuous monitoring system for measuring nitrogen oxides emissions is not required. If the initial performance test results show that nitrogen oxide emissions are greater than 70 percent of the applicable standard, the owner or operator shall install a continuous monitoring system for nitrogen oxides within one year after the date of the initial performance tests under §60.8 and comply with all other applicable monitoring requirements under this part.

### § 60.45

- (4) If an owner or operator does not install any continuous monitoring systems for sulfur oxides and nitrogen oxides, as provided under paragraphs (b)(1) and (b)(3) or paragraphs (b)(2) and (b)(3) of this section a continuous monitoring system for measuring either oxygen or carbon dioxide is not required.
- (c) For performance evaluations under §60.13(c) and calibration checks under §60.13(d), the following procedures shall be used:
- (1) Methods 6, 7, and 3B, as applicable, shall be used for the performance evaluations of sulfur dioxide and nitrogen oxides continuous monitoring systems. Acceptable alternative methods for Methods 6, 7, and 3B are given in §60.46(d).
- (2) Sulfur dioxide or nitric oxide, as applicable, shall be used for preparing calibration gas mixtures under Performance Specification 2 of appendix B to this part.
- (3) For affected facilities burning fossil fuel(s), the span value for a continuous monitoring system measuring the opacity of emissions shall be 80, 90, or 100 percent and for a continuous monitoring system measuring sulfur oxides or nitrogen oxides the span value shall be determined as follows:

[In parts per million]

Fossil fuel	Span value for sulfur dioxide	Span value for nitro- gen oxides
Gas	(1)	500
Liquid	1,000	500
Solid	1,500	1000
Combinations	1,000 <i>y</i> +1,500 <i>z</i>	500(x+y)+1,000z

<sup>&</sup>lt;sup>1</sup> Not applicable.

### where:

x=the fraction of total heat input derived from gaseous fossil fuel, and y=the fraction of total heat input derived

y=the fraction of total heat input derived from liquid fossil fuel, and

z=the fraction of total heat input derived from solid fossil fuel.

- (4) All span values computed under paragraph (c)(3) of this section for burning combinations of fossil fuels shall be rounded to the nearest 500 ppm.
- (5) For a fossil fuel-fired steam generator that simultaneously burns fossil fuel and nonfossil fuel, the span value of all continuous monitoring systems shall be subject to the Administrator's approval.
  - (d) [Reserved]

- (e) For any continuous monitoring system installed under paragraph (a) of this section, the following conversion procedures shall be used to convert the continuous monitoring data into units of the applicable standards (ng/J, lb/million Btu):
- (1) When a continuous monitoring system for measuring oxygen is selected, the measurement of the pollutant concentration and oxygen concentration shall each be on a consistent basis (wet or dry). Alternative procedures approved by the Administrator shall be used when measurements are on a wet basis. When measurements are on a dry basis, the following conversion procedure shall be used:

# $E=CF[20.9/(20.9-percent O_2)]$

#### where:

- E, C, F, and  $\%\text{O}_{2}$  are determined under paragraph (f) of this section.
- (2) When a continuous monitoring system for measuring carbon dioxide is selected, the measurement of the pollutant concentration and carbon dioxide concentration shall each be on a consistent basis (wet or dry) and the following conversion procedure shall be used.

# $E=CF_c$ [100/percent CO<sub>2</sub>]

### where:

- E, C, F  $_{c}$  and  $\%CO_{2}$  are determined under paragraph (f) of this section.
- (f) The values used in the equations under paragraphs (e) (1) and (2) of this section are derived as follows:
- (1) E=pollutant emissions, ng/J (lb/million Btu).
- (2) C=pollutant concentration, ng/dscm (lb/dscf), determined by multiplying the average concentration (ppm) for each one-hour period by  $4.15\times10^4$  M ng/dscm per ppm ( $2.59\times10^{-9}$  M lb/dscf per ppm) where M=pollutant molecular weight, g/g-mole (lb/lb-mole). M=64.07 for sulfur dioxide and 46.01 for nitrogen oxides.
- (3) %O<sub>2</sub>, %CO<sub>2</sub>=oxygen or carbon dioxide volume (expressed as percent), determined with equipment specified under paragraph (a) of this section.
- (4) F,  $F_c$ =a factor representing a ratio of the volume of dry flue gases generated to the calorific value of the fuel

# **Environmental Protection Agency**

combusted (F), and a factor representing a ratio of the volume of carbon dioxide generated to the calorific value of the fuel combusted ( $F_c$ ), respectively. Values of F and  $F_c$  are given as follows:

- (i) For anthracite coal as classified according to ASTM D388-77, 90, 91, 95, or 98a (incorporated by reference—see  $\S 60.17),~F=2,723\times 10^{-17}~dscm/J~(10,140~dscf/million~Btu~and~F_c=0.532\times 10^{-17}~scm~CO_2/J~(1,980~scf~CO_2/million~Btu).$
- (ii) For subbituminous and bituminous coal as classified according to ASTM D388-77, 90, 91, 95, or 98a (incorporated by reference—see  $\S60.17$ ), F=2.637×10 $^{-7}$  dscm/J (9,820 dscf/million Btu) and F<sub>c</sub>=0.486×10 $^{-7}$  scm CO<sub>2</sub>/J (1,810 scf CO<sub>2</sub>/million Btu).
- (iii) For liquid fossil fuels including crude, residual, and distillate oils,  $F=2.476\times10^{-7}$  dscm/J (9,220 dscf/million Btu) and  $F_c=0.384\times10^{-7}$  scm  $CO_2$ /J (1,430 scf  $CO_2$ /million Btu).
- (iv) For gaseous fossil fuels,  $F=2.347\times10^{-7}$  dscm/J (8,740 dscf/million Btu). For natural gas, propane, and butane fuels,  $F_c=0.279\times10^{-7}$  scm  $CO_2/J$

(1,040 scf  $CO_2$ /million Btu) for natural gas, 0.322×10  $^{-7}$  scm  $CO_2$ /J (1,200 scf  $CO_2$ /million Btu) for propane, and 0.338×10  $^{-7}$  scm  $CO_2$ /J (1,260 scf  $CO_2$ /million Btu) for butane.

- (v) For bark  $F{=}2.589{\times}10^{-7}~dscm/J~(9,640~dscf/million~Btu)~and <math display="inline">F_c{=}0.500{\times}10^{-7}~scm~CO_2/J~(1,840~scf~CO_2/million~Btu).$  For wood residue other than bark  $F{=}2.492{\times}10^{-7}~dscm/J~(9,280~dscf/million~Btu)$  and  $F_c{=}0.494{\times}10^{-7}~scm~CO_2/J~(1,860~scf~CO_2/~million~Btu).$
- (vi) For lignite coal as classified according to ASTM D388-77, 90, 91, 95, or 98a (incorporated by reference—see  $\S\,60.17),~F=2.659\times10^{-7}~dscm/J~(9,900~dscf/million~Btu)~and~F_c=0.516\times10^{-7}~scm~CO_2/J~(1,920~scf~CO_2/million~Btu).$
- (5) The owner or operator may use the following equation to determine an F factor (dscm/J or dscf/million Btu) on a dry basis (if it is desired to calculate F on a wet basis, consult the Administrator) or  $F_c$  factor (scm  $CO_2/J$ , or scf  $CO_2$ /million Btu) on either basis in lieu of the F or  $F_c$  factors specified in paragraph (f)(4) of this section:

$$F = 10^{-6} \frac{\left[227.2 \text{ (pct. II)} + 95.5 \text{ (pct. C)} + 35.6 \text{ (pct. S)} + 8.7 \text{ (pct. N)} - 28.7 \text{ (pct. O)}\right]}{\text{GCV}}$$

$$F_c = \frac{2.0 \times 10^{-5} \text{ (pct. C)}}{\text{GCV} \text{(SI units)}}$$

$$F = \frac{10^6 \left[3.64 (\% H) + 1.53 (\% C) + 0.57 (\% S) + 0.14 (\% N) - 0.46 (\% O)\right]}{\text{GCV} \text{(English units)}}$$

$$F_c = \frac{20.0 (\% C)}{\text{GCV} \text{(SI units)}}$$

$$F_c = \frac{321 \times 10^3 (\% C)}{\text{GCV} \text{(English units)}}$$

(i) H, C, S, N, and O are content by weight of hydrogen, carbon, sulfur, nitrogen, and oxygen (expressed as percent), respectively, as determined on the same basis as GCV by ultimate analysis of the fuel fired, using ASTM D3178-73 (Reapproved 1979), 89, or D3176-74 or 89 (solid fuels) or computed from results using ASTM D1137-53 or 75, D1945-64, 76, 91, or 96 or D1946-77 or

90 (Reapproved 1994) (gaseous fuels) as applicable. (These five methods are incorporated by reference—see §60.17.)

(ii) GVC is the gross calorific value (kJ/kg, Btu/lb) of the fuel combusted determined by the ASTM test methods D2015-77 for solid fuels and D1826-77 for gaseous fuels as applicable. (These two methods are incorporated by reference—see § 60.17.)

### § 60.46

(iii) For affected facilities which fire both fossil fuels and nonfossil fuels, the F or  $F_c$  value shall be subject to the Administrator's approval.

(6) For affected facilities firing combinations of fossil fuels or fossil fuels and wood residue, the F or  $F_c$  factors determined by paragraphs (f)(4) or (f)(5) of this section shall be prorated in accordance with the applicable formula as follows:

$$F = \sum_{i=1}^{n} X_i F_i \text{ or } F_c = \sum_{i=1}^{n} X_i (F_c)_i$$

where:

 $X_i$ =the fraction of total heat input derived from each type of fuel (e.g. natural gas, bituminous coal, wood residue, etc.)

 $F_i$  or  $(F_c)_i$ =the applicable F or  $F_c$  factor for each fuel type determined in accordance with paragraphs (f)(4) and (f)(5) of this section.

n=the number of fuels being burned in combination.

- (g) Excess emission and monitoring system performance reports shall be submitted to the Administrator semi-annually for each six-month period in the calendar year. All semiannual reports shall be postmarked by the 30th day following the end of each six-month period. Each excess emission and MSP report shall include the information required in §60.7(c). Periods of excess emissions and monitoring systems (MS) downtime that shall be reported are defined as follows:
- (1) Opacity. Excess emissions are defined as any six-minute period during which the average opacity of emissions exceeds 20 percent opacity, except that one six-minute average per hour of up to 27 percent opacity need not be reported.
- (i) For sources subject to the opacity standard of §60.42(b)(1), excess emissions are defined as any six-minute period during which the average opacity of emissions exceeds 35 percent opacity, except that one six-minute average per hour of up to 42 percent opacity need not be reported.
- (ii) For sources subject to the opacity standard of §60.42(b)(2), excess emissions are defined as any six-minute period during which the average opacity of emissions exceeds 32 percent opacity, except that one six-minute average

per hour of up to 39 percent opacity need not be reported.

- (2) Sulfur dioxide. Excess emissions for affected facilities are defined as:
- (i) Any three-hour period during which the average emissions (arithmetic average of three contiguous one-hour periods) of sulfur dioxide as measured by a continuous monitoring system exceed the applicable standard under § 60.43.
- (3) Nitrogen oxides. Excess emissions for affected facilities using a continuous monitoring system for measuring nitrogen oxides are defined as any three-hour period during which the average emissions (arithmetic average of three contiguous one-hour periods) exceed the applicable standards under §60.44.

[40 FR 46256, Oct. 6, 1975]

EDITORIAL NOTE 1: For FEDERAL REGISTER citations affecting §60.45, see the List of CFR Sections Affected, which appears in the Finding Aids section of the printed volume and on GPO Access.

EDITORIAL NOTE 2: At 65 FR 61752, Oct. 17, 2000, §60.45(f)(5)(ii) was amended by revising the words "ASTM D1826-77" to read "ASTM D1826-77 or 94." and by revising the words "ASTM D2015-77" to read "ASTM D2015-77 (Reapproved 1978), 96, or D5865-98." However, this amendment could not be incorporated because these words do not exist in paragraph (f)(5)(ii).

## § 60.46 Test methods and procedures.

- (a) In conducting the performance tests required in §60.8, the owner or operator shall use as reference methods and procedures the test methods in appendix A of this part or other methods and procedures as specified in this section, except as provided in §60.8(b). Acceptable alternative methods and procedures are given in paragraph (d) of this section.
- (b) The owner or operator shall determine compliance with the particulate matter,  $SO_2$ , and  $NO_X$  standards in §§ 60.42, 60.43, and 60.44 as follows:
- (1) The emission rate (E) of particulate matter,  $SO_2$ , or  $NO_X$  shall be computed for each run using the following equation:

 $E=C F_d (20.9)/(20.9-\% 0_2)$ 

E = emission rate of pollutant, ng/J (1b/million Btu).